


CO₂ Capture: Comparison of Cost & Performance of Gasification and Combustion-based Plants



*Workshop on Gasification
Technologies*

Indianapolis, Indiana

June 12-13, 2007

Jared Ciferno
National Energy Technology Laboratory



Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference therein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed therein do not necessarily state or reflect those of the United States Government or any agency thereof.



CO₂ Capture from Fossil Energy Power Plants

-Report Contains-


Subcritical PC

Supercritical PC

IGCC

NGCC

- Consistent design requirements
- Up-to-date performance and capital cost estimates
- Technologies built now and deployed by 2010



Study Matrix

Plant Type	ST Cond. (psig/°F/°F)	GT	Gasifier/ Boiler	Acid Gas Removal/ CO ₂ Separation / Sulfur Recovery	CO ₂ Cap
IGCC	1800/1050/1050 (non-CO ₂ capture cases)	F Class	GE	Selexol / - / Claus	
				Selexol / Selexol / Claus	90%
	CoP E-Gas		MDEA / - / Claus		
			Selexol / Selexol / Claus	88% ¹	
	1800/1000/1000 (CO ₂ capture cases)		Shell	Sulfinol-M / - / Claus	
				Selexol / Selexol / Claus	90%
PC	2400/1050/1050		Subcritical	Wet FGD / - / Gypsum	
				Wet FGD / Econamine / Gypsum	90%
	3500/1100/1100		Supercritical	Wet FGD / - / Gypsum	
				Wet FGD / Econamine / Gypsum	90%
NGCC	2400/1050/950	F Class	HRSG		
				- / Econamine / -	90%

¹ CO₂ capture is limited to 88% by syngas CH₄ content

GEE – GE Energy
CoP – Conoco Phillips



Design Basis: Bituminous Coal Type

Illinois #6 Coal Ultimate Analysis (weight %)

	As Rec'd	Dry
Moisture	11.12	0
Carbon	63.75	71.72
Hydrogen	4.50	5.06
Nitrogen	1.25	1.41
Chlorine	0.29	0.33
Sulfur	2.51	2.82
Ash	9.70	10.91
Oxygen (by difference)	6.88	7.75
	100.0	100.0
HHV (Btu/lb)	11,666	13,126



Environmental Targets

	IGCC ¹	PC ²	NGCC ³
SO ₂	0.0128 lb/MMBtu	0.085 lb/MMBtu	Negligible
NOx	15 ppmv (dry) @ 15% O ₂	0.07 lb/MMBtu	2.5 ppmv @ 15% O ₂
PM	0.0071 lb/MMBtu	0.013 lb/MMBtu	Negligible
Hg	> 90% capture	1.14 lb/TBtu	Negligible

¹ Based on EPRI's CoalFleet User Design Basis Specification for Coal-Based IGCC Power Plants

² Based on BACT analysis, exceeding new NSPS requirements


³ Based on EPA pipeline natural gas specification and 40 CFR Part 60



Technical Approach

1. Extensive Process Simulation (ASPEN)

- All major chemical processes and equipment are simulated
- Detailed mass and energy balances
- Performance calculations (auxiliary power, gross/net power output)



2. Cost Estimation

- Inputs from process simulation (Flow Rates/Gas Composition/Pressure/Temp.)
- Sources for cost estimation
 - Parsons
 - Vendor sources where available
- Follow DOE Analysis Guidelines

Economic Assumptions

Startup	2010
Plant Life (Years)	20
Capital Charge Factor, %	
High Risk	
(All IGCC, PC/NGCC with CO₂ capture)	17.5
Low Risk	
(PC/NGCC without CO₂ capture)	16.4
Dollars (Constant)	2007
Coal (\$/MM Btu)	1.80
Natural Gas (\$/MM Btu)	6.75
Capacity Factor	
IGCC	80
PC/NGCC	85



Total Plant Cost

- **Includes**

- Equipment
 - Initial chemicals and catalyst loadings
- Materials
- Labor
 - Direct and Indirect
- Engineering and Construction Management
- Project and Process Contingencies

- **Excludes**

- Owner's costs
 - Land, licensing and permitting, AFUDC
- Escalation to period of performance
- Taxes (except payroll)
- Site specific considerations
- Labor incentives in excess of 5 day/10 hour work week
- EPC premiums

IGCC Power Plant


Current State CO₂ Capture Using Selexol

Pre-Combustion CO₂ Capture Baseline



Current Technology

IGCC Power Plant



Process Design Assumptions:

Dual Train: 2 gasifiers, 2 Comb. Turbine, 1 Steam Turbine

Oxygen: 95% O₂ via Cryogenic ASU, ~4-7% Air Extraction from combustion turbine


Turbines: Advanced F-Class Turbine - 232MWe
 N₂ dilution employed to full extent in all cases
 Humidification/steam injection used only when necessary to meet syngas specification of ~120 Btu/scf LHV

Steam: 1800psig/1050°F/1050°F



Pre-Combustion Current Technology

IGCC Power Plant with CO₂ Scrubbing



CO₂ Capture Advantages:

1. High P_{CO₂}
2. Low Volume Syngas Stream
3. CO₂ Produced at Pressure

Process Design Assumptions:

Oxygen: 95% O₂ via Cryogenic ASU, No air extraction from combustion turbine

Steam: 1800psig/1000°F/1000°F

CO₂ Compression: 2,200 Psig

Gross Power (MW)


2 Comb. Turbines: 464
1 Stm. Turbine: 200-300



Water-Gas Shift Reactor System

Design:

- Haldor Topsoe SSK Sulfur Tolerant Catalyst
- Up to 97.5% CO Conversion
- 2 stages for GE and Shell, 3 stages for E-Gas
- $H_2O/CO = 2.0$ (Project Assumption)
- Overall $\Delta P = \sim 30$ psia



*High Pressure Steam




CO₂ Capture via Selexol Scrubbing

Advantages


- Physical Liquid Sorbent → High loadings at high CO₂ partial pressure
- Highly selective for H₂S and CO₂ → No need for separate sulfur capture system
- No heat of reaction (ΔH_{rxn}), small heat of solution
- Chemically and thermally stable, low vapor pressure
- 30+ years of commercial operation (55 worldwide plants)

Disadvantages

- Requires Gas Cooling (to ~100°F)
- CO₂ regeneration by flashing



Selexol™ Scrubbing



GE Energy IGCC Performance Results

	GE Energy	
CO ₂ Capture	NO	YES
Gross Power (MW)	770	745
Auxiliary Power (MW)		
Base Plant Load	23	23
Air Separation Unit	103	121
Gas Cleanup/CO ₂ Capture	4	18
CO ₂ Compression	-	27
Total Aux. Power (MW)	130	189
Net Power (MW)	640	556
Heat Rate (Btu/kWh)	8,922	10,505
Efficiency (HHV)	38.2	32.5
Energy Penalty ¹	-	5.7

Steam for WGS,
Selexol Unit

↑ in ASU air comp.
load w/o turbine
integration

Includes H₂S/CO₂
Removal in Selexol
Solvent

¹CO₂ Capture Energy Penalty = Percent points decrease in net power plant efficiency due to CO₂ Capture



IGCC Performance Summary


	GE Energy		E-Gas		Shell	
CO ₂ Capture	NO	YES	NO	YES	NO	YES
Gross Power (MW)	770	745	743	694	748	694
Auxiliary Power (MW)						
Base Plant Load	23	23	25	26	21	19
Air Separation Unit	103	121	91	109	90	113
Gas Cleanup/CO ₂ Capture	4	18	3	15	1	16
CO ₂ Compression	-	27	-	26	-	28
Total Aux. Power (MW)	130	189	119	176	112	176
Net Power (MW)	640	556	623	518	636	517
Heat Rate (Btu/kWh)	8,922	10,505	8,681	10,757	8,304	10,674
Efficiency (%HHV)	38.2	32.5	39.3	31.7	41.1	32.0
Energy Penalty¹	-	5.7	-	7.6	-	9.1

¹CO₂ Capture Energy Penalty = Percent points decrease in net power plant efficiency due to CO₂ Capture

CO₂ Capture decreases net efficiency by ~6-9 percentage points



Water Usage in IGCC Plants



IGCC Economic Results

Total Plant Cost

	GE Energy		E-Gas		Shell	
CO ₂ Capture	NO	YES	NO	YES	NO	YES
Plant Cost (\$/kWe)¹						
Base Plant	1,323	1,566	1,272	1,592	1,522	1,817
Air Separation Unit	287	342	264	329	256	336
Gas Cleanup/CO ₂ Capture	203	414	197	441	199	445
CO ₂ Compression	-	68	-	69	-	70
Total Plant Cost (\$/kWe)	1,813	2,390	1,733	2,431	1,977	2,668
Increase in TPC (\$/kWe)	-	577	-	698	-	691



IGCC Economic Results

Cost of Electricity

	GE Energy		E-Gas		Shell	
CO ₂ Capture	NO	YES	NO	YES	NO	YES
Total Plant Cost (\$/kWe)	1,813	2,390	1,733	2,431	1,977	2,668
Plant Capital COE (¢/kWh)	4.53	5.97	4.33	6.07	4.94	6.66
Plant O&M COE (¢/kWh)	3.27	3.93	3.20	4.09	3.11	3.97
Total Plant COE (¢/kWh)	7.80	9.90	7.53	10.16	8.05	10.63
CO ₂ TS&M COE (¢/kWh)	-	0.39	-	0.41	-	0.41
Total COE ² (¢/kWh)	7.80	10.29	7.53	10.57	8.05	11.04
Increase in COE (¢/kWh)	-	2.49	-	3.04	-	2.99
Increase in COE (%)	-	32	-	40	-	37
\$/ton CO ₂ Avoided	-	32	-	41	-	42

CO₂ transport, storage and monitoring adds <0.5 ¢/kWh
 Increase in COE ~ 3 cents/kWh (~ ↑36%)



Pulverized Coal Power Plant


***Current State* CO₂ Capture Using Advanced Amines**

Post-Combustion CO₂ Capture Baseline



Post-Combustion Current Technology

Pulverized Coal Power Plant with CO₂ Scrubbing



Process Design Assumptions:

Steam:

Subcritical → 2400psig/1050°F/1050°F

Supercritical → 3500psig/1100°F/1100°F

CO₂ Capture Challenges:

1. Dilute Flue Gas (10-14% CO₂)
2. Low Pressure CO₂
3. 1.5 Million scfm
4. 17,000 ton CO₂/day removed
5. Large Parasitic Loads (Steam + CO₂ Compression)

Amine Scrubbing Advantages/Disadvantages

Amine Advantages

1. Proven Technology → Remove CO₂ and H₂S from NG
2. Chemical solvent → *High* loadings at *low* CO₂ partial pressure
3. Relatively Cheap (\$1.50-2.0 per lb chemical)

Amine Disadvantages

1. High heat of reaction → high regeneration energy required
 - 1,500 to 3,500 Btu/lb CO₂ removed
 - Low pressure steam derates power plant by 20 to 40%
2. Degradation and Corrosion
 - Requires < 10ppm sulfur
3. High cost




Amine Scrubbing Improvements

Amine CO₂ scrubbing technology leaders are Fluor (Econamine FG PlusSM) and Mitsubishi Heavy Industry

Improvements	Benefits	Outcome
1. New Solvent Formulation	↑ Reaction Rates	↓ Packing volume, ↓ Absorber size ↓ Absorber cost
	↑ CO ₂ Capacity	↓ Solvent circulation, ↓ Reboiler Duty
2. Heat Integration	↑ Reaction Rates	↓ Packing volume, ↓ Absorber size ↓ Absorber cost
	↑ CO ₂ Capacity	↓ Solvent circulation, ↓ Reboiler Duty
3. Split Flow	↓ Reboiler Duty	↑ Power plant efficiency
4. Condensate Flash Steam Stripping	↓ Semi-Lean Loading	↓ Reboiler Duty
5. Integrated Steam Generation	↓ Reboiler Duty	↑ Power plant efficiency
6. Larger Diameter Vessels	60 foot diameter	Accommodate power plants
7. Non-Thermal Reclaimer	↓ Solvent Losses	↓ Solvent make-up costs, eliminate any solid hazardous waste



Fluor Econamine FG PlusSM Scrubbing



Reboiler Heat Duty (Btu/lb CO ₂)	1,550	Regeneration (°F)	250's
MEA Circulation Rate (GPM)	35,000	Auxiliary Power (MW)	21-24
Absorption (°F)	100's	Induced Draft Fan (MW)	13-15



Subcritical PC Performance

	Subcritical	
Coal Flow Rate (Ton/day)	5,252	7,759
CO ₂ Captured (Ton/day)	0	16,566
Gross Power (MW)	583	680
Auxiliary Power (MW)		
Base Plant Load	21	35
Forced + Induced Draft Fans	9	14
Flue Gas Cleanup	3	5
CO ₂ Capture	-	24
CO ₂ Compression	-	52
Total Aux. Power (MW)	33	130
Net Power (MW)	550	550
Efficiency (%HHV)	36.8	24.9
Energy Penalty (% Points)	-	11.9

48% Increase in Coal Feed Rate

Larger Base Plant

MEA Scrubbing

~17,000 TPD to 2,200 Psig

CO₂ Capture decreases net efficiency by ~12 percentage points




Pulverized Coal Performance Summary

	Subcritical		Supercritical	
Coal Flow Rate (Ton/day)	5,252	7,759	4,935	7,039
CO ₂ Captured (Ton/day)	0	16,566	0	15,029
Gross Power (MW)	583	680	580	663
Auxiliary Power (MW)				
Base Plant Load	21	35	18	32
Forced + Induced Draft Fans	9	14	9	13
Flue Gas Cleanup	3	5	3	4
CO ₂ Capture	-	24	-	21
CO ₂ Compression	-	52	-	47
Total Aux. Power (MW)	33	130	30	117
Net Power (MW)	550	550	550	546
Efficiency (%HHV)	36.8	24.9	39.1	27.2
Energy Penalty (% Points)	-	11.9	-	11.9

CO₂ Capture decreases net efficiency by ~12 percentage points



Water Usage in PC and IGCC Plants



Pulverized Coal Economic Results Summary

Total Plant Cost

	Subcritical		Supercritical	
CO ₂ Capture	NO	YES	NO	YES
Plant Cost (\$/kWe)				
Base Plant	1,303	1,691	1,346	1,731
SO _x and NO _x Cleanup	246	323	229	302
CO ₂ Capture	-	792	-	752
CO ₂ Compression	-	89	-	85
Total Plant Cost (\$/kWe)	1,549	2,895	1,575	2,870
Increase in TPC (\$/kWh)	-	1,346	-	1,295




Pulverized Coal Economic Results Summary

	Subcritical		Supercritical	
CO ₂ Capture	NO	YES	NO	YES
Total Plant Cost (\$/kWe)	1,549	2,895	1,575	2,870
Plant Capital COE (¢/kWh)	3.41	6.81	3.47	6.75
Plant O&M COE (¢/kWh)	2.99	4.64	2.86	4.34
Total Plant COE (¢/kWh)	6.40	11.45	6.33	11.09
CO ₂ TS&M COE (¢/kWh)	0.00	0.43	0.00	0.39
Total COE (¢/kWh)	6.40	11.88	6.33	11.48
Increase in COE (¢/kWh %)	-	5.48	-	5.15
Increase in COE (%)	-	86	-	81
\$/ton CO ₂ Avoided		68		68


CO₂ transport, storage and monitoring adds <0.5 ¢/kWh
 Increase in COE ~ 5 cents/kWh (~ 184%)



Net Efficiency Comparison




Average Total Plant Cost Comparison



Total Plant Capital Cost includes contingencies and engineering fees



Average Cost of Electricity Comparison



NETL Viewpoint

- **Establishes baseline performance and cost estimates for current state of technology**
- **Improved efficiencies and reduced costs are required to improve competitiveness of advanced coal-based systems**
 - In today's market and regulatory environment
 - Also in a carbon constrained scenario
- **Fossil Energy RD&D aimed at improving performance and cost of clean coal power systems including development of new approaches to capture and sequester greenhouse gases**



Thank You!

Email: Jared.Ciferno@netl.doe.gov

Phone: 412-386-5862

NETL Energy Analysis Link:

www.netl.doe.gov/energy-analyses



Supplemental Slides



Contracting Approach

- **EPCM vs. EPC**
 - EPCM (engineering, procurement, construction management)
 - Owner has control of project
 - Risk is reduced with time as scope definition improves by time of contract award
 - EPC (engineer, procure, construct)
 - Lump sum contract where contractor assumes all risk for performance, schedule, and cost
 - If willing to accept risk, premiums applied can raise costs dramatically
- **This study assumes EPCM so costs do not include “risk wrap”**



Pulverized Coal Economic Results Summary

	Subcritical		Supercritical	
CO ₂ Capture	NO	YES	NO	YES
Plant Cost (\$/kWe)				
Base Plant	1,303	1,691	1,346	1,731
SOx and NOx Cleanup	246	323	229	302
CO ₂ Capture	-	792	-	752
CO ₂ Compression	-	89	-	85
Total Plant Cost (\$/kWe)	1,549	2,895	1,575	2,870
Capital COE (¢/kWh)				
Capital COE (¢/kWh)	3.41	6.81	3.47	6.75
O&M COE (¢/kWh)	2.99	4.64	2.86	4.34
CO ₂ TS&M COE (¢/kWh)	0.00	0.43	0.00	0.39
Total LCOE (¢/kWh)	6.40	11.88	6.33	11.48
Increase in COE (%)	-	86	-	81
\$/ton CO ₂ Avoided		68		68



IGCC Economic Results

	GE Energy		E-Gas		Shell	
CO ₂ Capture	NO	YES	NO	YES	NO	YES
Plant Cost (\$/kWe)¹						
Base Plant	1,323	1,566	1,272	1,592	1,522	1,817
Air Separation Unit	287	342	264	329	256	336
Gas Cleanup/CO ₂ Capture	203	414	197	441	199	445
CO ₂ Compression	-	68	-	69	-	70
Total Plant Cost (\$/kWe)	1,813	2,390	1,733	2,431	1,977	2,668
Capital COE (¢/kWh)						
Capital COE (¢/kWh)	4.53	5.97	4.33	6.07	4.94	6.66
Variable COE (¢/kWh)	3.27	3.93	3.20	4.09	3.11	3.97
CO₂ TS&M COE (¢/kWh)	0.00	0.39	0.00	0.41	0.00	0.41
Total COE² (¢/kWh)	7.80	10.29	7.53	10.57	8.05	11.04
Increase in COE (%)	-	32	-	40	-	37
\$/tonne CO₂ Avoided	-	35	-	45	-	46

¹Total Plant Capital Cost (Includes contingencies and engineering fees)

²January 2007 Dollars, 80% Capacity Factor, 17.5% Capital Charge Factor, Coal cost \$1.80/10⁶Btu

